



Newcon Consultants & Laboratories

(GOVERNMENT APPROVED TESTING LABORATORIES)
An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified Laboratory



TC-12621

TEST REPORT

Page No.: 1 of 1

TEST REPORT No. NCL/EP-057/20/02/25		DATE OF REPORT : 25/02/2025
Name and Address of Customer	M/S AL NOOR HOSPITAL K.P Road, Distt-Anantnag	

SAMPLING DETAILS

Sample Name : EFFLUENT WATER
 Analysis Start Date : 20/02/2025 Analysis End Date : 25/02/2025
 Date of Sampling : 18/02/2025 Sample ID No. : NCL/EP-057/20/02/25
 Time of Sampling : 11:00 AM Sample Receipt Date : 20/02/2025
 Sampling Done By : NCL Environmental Condition : 27±2°C
 Sample Description : EFFLUENT WATER BEFORE TREATMENT
 Sampling Location : ETP INLET
 Sampling Protocol : IS:17614 (P-1) Sample Quantity : 2 Ltr
 Packing Condition : Sealed Packing : PVC CANE

TEST RESULT

S.No.	Test Parameters	Unit	Test Method	Results
1	pH	-	IS : 3025 (P-11)	6.60
2	Total Suspended Solids (TSS)	mg/L	IS : 3025 (P-17)	50
3	Bio Chemical Oxygen Demand (3 Days at 27°C)	mg/L	IS : 3025 (P-44)	220
4	Chemical Oxygen Demand (COD)	mg/L	APHA-5220 B	900
5	Oil & Grease	mg/L	IS : 3025 (P-39)	9
6	Phosphate (as P)	mg/L	APHA-4500 P(D)	2.5
7	Nitrate Nitrogen (NO3)	mg/L	IS:3025 (P-34)	20.6

End of Report

EP-057/20/02/25-1



SONU
Section Incharge
Checked by

FOR NEWCON CONSULTANTS & LABORATORIES

Authorized Signatory



1. The test report refers only to the particular sample/s submitted for testing and listed parameters.
2. Endorsement of the same is neither inferred nor implied.
3. Laboratory shall maintain the confidentiality of all information related to the samples & test reports.
4. Complaints about this report should be communicated within 10 days of the issue date of this report.
5. The report is not to be produced wholly or in part without prior permission of the Managing Partner. All disputes subject to Ghaziabad Jurisdiction.